

### ADDENDUM NO. 3 TO THE IFB #2020-1486

The Alameda-Contra Costa Transit District herewith issues this Addendum No. 3 to the above-referenced INVITATION FOR BID. Except as modified below, all other terms and conditions remain in effect. Strikethrough text represents deletions from the original IFB, and ***bold/italicized/underlined text*** represent additions to original IFB text.

#### **CLARIFICATIONS**

**1) Prime Proposer & Sub-Proposer/Supplier Report:**

Please complete all information requested on the Prime Proposer and Sub-Proposer/Supplier Report attachment. As stated on that attachment, page 18 of IFB 2020-1486 Bid Manual, "Complete All Fields or Indicate N/A. Do Not Leave Blanks."

**2) Fencing**

Sheet SD3 Fence Details-Note 5, the fencing will be a security mesh located on gate and adjacent panel only. Material specification: expanded steel mesh, minimum ¾" Long Way Diamond, minimum weight per square foot: 2.0 pounds per square foot, hot-dip galvanized.

On Sheet SD3, Fence Details-Note 4, the wedge anchor bolts depth embedment shall be 3/8" thick, 7"x7" steel baseplate, four each 3/8" dia. stainless steel wedge anchor with minimum 2.5" embedment.

**3) Access Control Equipment**

On Sheet SD3 Fence Details-Note 6, the manufacturer and model # for the card reader and lever handle are listed below:

- Access Control Equipment Manufacturer: Genetec or approved equal, MFG Part# 920NMNNEKMA001, Card Reader-MSRP no keypad.
- The Lever lock set: Schlage Latitude Single Cylinder Keyed Entry Door Lever (model F51ALAT622 or equal.)