

Training and Education Center Roof Replacement

ADDENDUM NO.5 DATED AUGUST 2, 2019

The Alameda-Contra Costa Transit District hereby issues this **Addendum No. 5** to the above referenced INVITATION FOR BID. Except as modified below, all other terms and conditions remain in effect. Strikethrough text represents deletions from the original IFB, and ***bold/italicized/underlined text*** represent additions to original IFB text.

1. **CHANGE on Page 1 of 131:**

Section 00 11 16, is revised to read as follows:

NOTICE IS HEREBY GIVEN THAT sealed Bids will be received by the Alameda-Contra Costa Transit District (hereinafter "AC Transit" or the "District") at 1600 Franklin Street, 6th Floor, Oakland, California 94612, until ***August 15, 2019 at 1:00 PM PST*** ~~August 8, 2019 at 4:00 PM PST~~ at which time Bids will be publicly opened and read for the following project:

2. **RESPONSES TO QUESTIONS/CLARIFICATIONS AFTER 2ND PRE-BID CONFERENCE**

Q1) *Can the District advise if the awardee will be required to install insulation on the roof before installing insulated roof panels?*

A1) **The roof panels are internally insulated panels, which replace the existing batt insulation. There is some additional insulation in the curbs for the skylights, see sheet A8.1. There may also be some insulation replacement in the walls, related to the decay repairs.**

END OF ADDENDUM NO. 5